

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Smt Sume Hegde Microbiologist
(Name of Officers with designation) from Dist. Health and family welfare dept udupi
(Name of Department/ Office) inspected the ST Cecily's English medium Higher Primary School.
(Name & Address of the school) on 17/08/2022 (date of inspection) and found that the
filter water (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 3 to 6 months as per AMC conditions of the filter company.


Microbiologist
District Surveillance Unit
Udipi District 576 101

Signature with Seal:



Name

District Surveillance Officer

Designation


District Surveillance officer

Name & Address of the Office / Department:

Health & family welfare office, udupi

To

ST CECILY'S ENGLISH MEDIUM HIGHER PRIMARY SCHOOL.
Borhmaguzi udupi


JOINT SECRETARY
THE APOSTOLIC CARMEL EDUCATIONAL SOCIETY (REGD) KARNATAKA
ST CECILY'S ENGLISH MEDIUM HR PRY SCHOOL
UDUPI - 576 101

Teeritha AC
PRINCIPAL
ST. CECILY'S ENGLISH MEDIUM
HR. PRY. SCHOOL
UDUPI - 576 101



DISTRICT SURVEILLANCE UNIT

Priority- Laboratory

Udupi District.

Ph:-0820-2520561,2525561 Email:-dsoudupi@yahoo.co.in

No.Dso/Water/ 286 /2022-23

Date:-19-08-2022

To
Principal
St.Cecily's English Medium
Higher Primary School Udupi

REPORT OF BACTERIOLOGICAL ANALYSIS OF WATER						
SI NO	Sample No	Place of collection	Source of water	Date of Collection	MPN COUNT/ 100ml	Result
1	405	St.Cecily's English Medium Higher Primary School, Bramhagiri, Udupi	Filter Water	17-08-2022	0	Excellent

Note	M.P.N COUNT	Most Probable number of Bacteria Per 100ml Of Water
	S.P.P	Satisfactory For Potable Purposes
	N.S.P.P	Not Satisfactory For Potable Purposes

Class 1	Excellent	0
Class 2	Satisfactory	1 to 3
Class 3	Suspicious	4 to 10
Class 4	UnSatisfactory	Greater than 10

Suma Hegde
Microbiologist

District Surveillance Unit Udupi

Dr. Nagarathna
District Surveillance Officer,
Udupi District Udupi.

JOINT SECRETARY
THE APOSTOLIC CARMEL EDUCATIONAL
SOCIETY (REGD) KARNATAKA
ST CECILY'S ENGLISH MEDIUM HR PRY SCHOOL
UDUPI - 576 101

Jeevintha Ac
PRINCIPAL
ST. CECILY'S ENGLISH MEDIUM
HR. PRY. SCHOOL
UDUPI - 576 101



ನಗರಸಭಾ ಕಾರ್ಯಾಲಯ, ಉಡುಪಿ.

ಉಡುಪಿ ಜಿಲ್ಲೆ - 576101



b : www.udupicity.mrc.gov.in
Mail : itstaff_ulb_udupi@yahoo.com

Phone : 0820-2520446/2520306
Fax : 0820-2524236


No: UCMC/HLH2/CR-424/2022-23

Dated: 04.08.2022


To Whom So Ever It May Concern


This is to certified that, as per inspection report of the Sr. Health Inspector CMC, Udupi, " St Cecily's English Medium Higher Primary School" Brahmagiri, Udupi, Karnataka -576101, is maintaining hygienic sanitation condition in the school building and the campus as per the norms prescribed by the State.

This certificate is issued based on the request from Headmistress, St. Cecily's English Medium Higher Primary School, Udupi and valid for a period of one year.


Municipal Commissioner
Municipal Commissioner
City Municipal Council
UDUPI

To,
Headmistress,
St. Cecily's English Medium Higher Primary School,
Udupi - 576101.
Ph: 0820-2524022.


JOINT SECRETARY
THE APOSTOLIC CARMEL EDUCATIONAL
SOCIETY (REGD) KARNATAKA
ST CECILY'S ENGLISH MEDIUM HR PRY SCHOOL
UDUPI - 576 101


PRINCIPAL
ST. CECILY'S ENGLISH MEDIUM
HR. PRY. SCHOOL
UDUPI - 576 101